



2025 ANNUAL DRINKING WATER QUALITY REPORT

Revised 4/28/2026

Re: 2025 Water Quality Report – Town of Gulf Stream

Dear Residents:

We are pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality of water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water.

The Town of Gulf Stream purchases its water from the City of Delray Beach Utilities. The City of Delray Beach withdraws water from a shallow, under-ground source called the East Coast Surficial Aquifer. There are 30 raw water wells located throughout the City from which water is drawn and piped to the water treatment plant. The Delray Beach Treatment Plant utilizes what is known as "Lime Softening Process" to treat raw water prior to distribution to its customers. Upon arrival at the Water Treatment Plant, the raw water is first aerated to remove natural gases. The water is then blended with lime in a clarifier for softening, color, and iron removal. After the blending process the water is then filtered and disinfected per Federal and State drinking water standards. Prior to distribution, Fluoride is injected to maintain one part per million to prevent tooth decay.

In 2025, The Florida Department of Environmental Protection (DEP) performed a Source Water Assessment of Delray's system. The assessment was conducted to provide information about any potential sources of contamination near the City's wells. There were 27 potential sources of contamination identified for the City's system, with low to moderate susceptibility levels, of which none are of concern at this time. The assessment results are available on the DEP Source Water Assessment and Protection Program website at www.prodapps.dep.state.fl.us/swapp.

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact the City of Delray Beach Water Plant 561-243-7318 or the Town Hall 561-276-5116.

The Town of Gulf Stream routinely monitors contaminants in your drinking water according to Federal and State laws, rules, and regulations. Except where indicated otherwise, this report is based on the results of our water monitoring for the period of January 1 to December 31, 2025. The data obtained, and presented in this report are from the most recent tests performed in accordance with the established drinking water laws, rules, and regulations.

The Town of Gulf Stream is responsible for testing total Coliform bacteria monthly and Lead and Copper every thirty-six (36) months in accordance with 40 CFR 141. Subpart I. The City of Delray Beach, the primary supplier, is responsible for the monitoring of additional Primary and Secondary contaminants prior to its delivery in accordance with reporting period of January 1 to December 31, 2025.

DEFINITIONS: The terms and abbreviations found in the following tables are defined here:

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminate Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) – one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) – one part by weight of analyte to 1 billion parts by weight of the water sample.

Action Level (AL) – the concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

ND – means not detected and indicates that the substance was not found in laboratory analysis.

A – Absent

The chart below shows substances that the EPA requires our utility to report. To determine how we compare to the federal regulation, compare the column that shows the highest level allowed by EPA (MCLs) to the column that shows the level detected at our utility during 2025, our last testing period.

Stage 1 Disinfectants and Disinfection By-Products							
*Data from analysis of test results for Gulf Stream							
For bromate, chloramines, or chlorine, the level detected is the highest running annual average (RAA), computed quarterly, of monthly averages of all samples collected. The range of results is the range of results of all the individual samples collected during the past year.							
Disinfectant or Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	MCL or MRDL Violation Y/N	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
Chlorine and Chloramines (ppm)	1/25-12/25	N	3.2	0.8 – 4.0	MRDLG = 4	MRDL = 4.0	Water additive used to control microbes

Stage 2 Disinfectants and Disinfection By-Products							
*Data from analysis of test results for Gulf Stream							
For HAA5 and TTHM, the level detected is the highest locational running annual average (LRAA), computed quarterly, of quarterly averages of all samples collected. Range of Results is the range of individual sample results (lowest to highest) for the monitoring locations.							
Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
*Total Trihalomethanes (TTHM) (ppb)	8/25	N	19.2	17.0 – 19.2	N/A	80	By-product of drinking water disinfection.
Haloacetic Acids (HAA5) (ppb)	8/25	N	30	18 – 30	N/A	60	By-product of drinking water disinfection.

Lead and Copper (Tap Water)							
*Data from analysis of Lead and Copper test results from 2025 sampling for Gulf Stream.							
Contaminant and Unit of Measurement	Dates of Sampling (mo/yr)	AL Exceeded Y/N	90 th Percentile Result	No. of Sampling Sites Exceeding the AL	MCLG	AL (Action Level)	Likely source of Contamination
Copper (tap water) (ppm)	03/25-09/25	N	0.042	0	1.3	1.3 mg/L	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead (tap water) (ppb)	03/25-09/25	N	0.0043	0	0	.010 mg/L	Corrosion of household plumbing systems, erosion of natural deposits

IMPORTANT INFORMATION:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Gulf Stream is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available on the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The source of drinking water (both tap water and bottled water) includes rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- a. Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.*
- b. Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.*
- c. Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff and residential uses.*
- d. Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.*
- e. Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.*

In order to ensure that tap water is safe to drink the EPA prescribes regulations to limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

*Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from Safe Drinking Water Hotline (1-800-426-4791).*

We at the Town of Gulf Stream work around the clock to provide top quality water to all our customers. We ask that you help us protect our water systems, which are the heart of our community, our way of life and our children's future.

TEST RESULTS							
2025 CCR - CITY OF DELRAY BEACH							
Primary Inorganic Contaminants¹							
Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL or MRDL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Arsenic (ppb)	02/23	N	0.72	N/A	0	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
Barium (ppm)	02/23	N	0.0091	N/A	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Fluoride (ppm)	02/23	N	0.54	N/A	4	4	Erosion of natural deposits; discharge from fertilizer and aluminum factories. Water additive which promotes strong teeth when at the optimum level of 0.7 ppm
Nitrate as Nitrogen (ppm)	09/25	N	0.072	N/A	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium (ppm)	02/23	N	31.8	N/A	N/A	160	Saltwater intrusion; leaching from soil.
Stage 2 Disinfectant/Disinfection By-Product (D/DBP) Parameters / Chloramines¹							
Disinfectant or Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL or MRDL Violation Y/N	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
Total Trihalomethanes (ppb)	02/25 -11/25	N	33.1	18.4 – 37.1	N/A	80	By-product of drinking water disinfection
Total Halo Acetic Acid (ppb)	02/25 -11/25	N	22.5	17.9 – 24.4	N/A	60	
Chloramines (ppm)	01/25 -12/25	N	3.7	1.54 – 5.2	4	4	Water additive used to control microbes.
Chlorite (ppm)	2/23	N	0.019	N/A	0.8	1	By-product of drinking water disinfection
Lead and Copper (Tap Water)							
Contaminant and Unit of Measurement	Dates of Sampling (mo./yr.)	AL Exceeded (Y/N)	90th % Percentile Result	No. of sampling sites exceeding the AL	MCLG	AL (Action Level)	Likely Source of Contamination
Lead (tap water) ppb	09/25	N	3.7	0	0	15	Corrosion of household plumbing systems and service lines connecting buildings to water mains; erosion of natural deposits
Copper (tap water) ppm	09/25	N	0.10	0	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.

1 - Results in the Level Detected column for inorganic contaminants, stage 2 disinfectant/disinfection by-product parameters and chloramines are the highest average at any of the sampling points or the highest detected level at any sampling point, depending on the sampling frequency.